

# Certificate

## EC-Type-Examination

acc. to Directive 97/23/EC

Zertifikat Nr.:

**01 202 642-B-11027**

Name and address of the  
manufacturer:

Goetze KG  
Armaturen  
Postfach 448  
71604 Ludwigsburg

We hereby certify, that the type example  
mentioned below meets the requirements of the  
Directive 97/23/EC.

Tested acc. to Directive 97/23/EC:

**EC-Type-Examination (Module B)**

Test report No.:

**642-11-516**

Description of type example:

**Safety Valve**

**Design:** direct acting, springloaded

**Type:** 651 HI und 651 HN

**Medium:** Hot Water from Water Boilers

acc. to EN 12828 (120° C, fluid group 2)

**Sizes:** DN 15, DN 20, DN 25, DN 32, DN 40, DN 50


**Set Pressure:** 2,5 up to 5 bar

Valid until:

12<sup>th</sup> December 2021

The CE marking must not be affixed and the Declaration of Conformity not be issued  
prior to completion of the corresponding conformity assessment procedure according to  
Directive 97/23/EC.

Aachen, 05th December 2011

  
Dipl.-Ing. Manfred Rönning



TÜV Rheinland-Certification Body for Pressure Equipment  
TÜV Rheinland Industrie Service GmbH, Notified Body, ID-No. 0035  
Am Grauen Stein, D-51105 Köln

Außenstelle

Krefelder Str. 225, 52070 Aachen, Tel. ++49-241/1825-870  
E-Mail: service-is-mw@de.tuv.com